



NOTES:

- When applying for a side sewer permit the applicant must Provide the following information:
 - Correct legal description
 - Correct site address
 - Tax parcel number
 - Accurate plot plan @20 scale showing the site and buildings to be connected.
- All plumbing outlets must be connected to the sewer.
- No downspouts, outside drains, or any surface or ground water will be permitted to enter the sewer system.
- 4" diameter sewer pipe is the minimum allowable size for residential and can be used to serve only one single family residence.
- 6" diameter sewer pipe for commercial side sewer is sufficient to serve up to 10 apartment units or four single family residences.
- Any sewer construction performed within the public right-of-way must be done by a contractor that has met all the Midway Sewer District licensing, bonding and insurance requirements w/ ROW permit from city.
- The following type of pipes are to be used for the construction of sewers.
 - Polyvinyl Chloride (PVC) NO GLUE JOINTS
 Pipe- ASTM D3034 SDR 35
 Joints- ASTM D3212
 Gaskets- ASTM F477
 - C900 PVC NO GLUE JOINTS
 Pipe- AWWA C900
 Joints- ASTM B3139
 Gaskets- ASTM F477
 - Acrylonitrile-Butadiene-Styrene (ABS)
 Pipe- ASTM D2751
 Joints- ASTM D3212
 Gaskets- ASTM F477
 Solvent Cement D2235

